

**FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS**  
 (Alternate Form for Single Chamber, Completely Shop-Fabricated Vessels Only)  
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured by The Stacey Manufacturing Company, Cincinnati, Ohio 45216  
 2. Manufactured for Foster Wheeler Energy Corp., Livingston, N.J. 07039  
 3. Location of Installation Philadelphia Gas Works, Philadelphia, Pa.  
 4. Type Vertical 4267 0-170-43 1308 (Year Built) 1977  
(Horiz. or vert. tank) (Mfr's Serial No.) (CRN) (Drawing No.) (Nat'l Brd No.)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1974 and Addenda to 12-31-76 and Code Case Nos. \_\_\_\_\_  
(Year) (Date)

Special Service per UG-120(d) \_\_\_\_\_  
 Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: \_\_\_\_\_

6. Shell: Matl. "See Remarks" Nom. Thk. 1 3/16 in. Allow. 5/64 in. Diam. 7'-0 in. Lgth. 14 ft 4 in.  
(Spec. No., Grade)

7. Seams: Long. Weld Dbl. Butt R.T. Spot Efficiency 85 % H.T. Temp. \_\_\_\_\_ F Time \_\_\_\_\_ hr  
(Welded, Dbl, Sngl, Lap, Butt) (Spot or Full)  
 Girth Welded Dbl. Butt R.T. Spot No. of Courses 2  
(Welded, Dbl, Sngl, Lap, Butt) (Spot, Partial, or Full)

8. Heads: (a) Material "See Remarks" (b) Material "See Remarks"  
(Spec. No., Grade) (Spec. No., Grade)

Location (Top, Bottom, Ends)	Min. Thk.	Corr. Allow.	Crown Radius	Knuckle Radius	Ellipse Ratio	Conical Apex Angle	Hemisp. Radius	Flat Diam.	Side to Pressure (Convex or Concave)
(a) <u>Top</u>	<u>1 3/16"</u>	<u>5/64"</u>			<u>2:1</u>				<u>Convex &amp; Concave</u>
(b) <u>Bottom</u>	<u>"</u>	<u>"</u>			<u>"</u>				<u>"</u>

If removable, bolts used (describe other fastenings) \_\_\_\_\_  
(Material, Spec. No., Gr., Size, No.)

9. Constructed for max. allowable working pressure F.V. & 375 psi at max. temp. 4000 F. Min. temp. (when less than -20 F) \_\_\_\_\_ F. Hydrostatic, pneumatic, or combination test pressure 563 psi.

10. Safety Valve Outlets: Number \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_

11. Nozzles and Inspection Openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Matl.	Nom. Thk.	Reinforcement Matl.	How Attached	Location
<u>Manway</u>	<u>1</u>	<u>20"</u>	<u>300#S.O.</u>	<u>SA-181-1</u>	<u>3/8"</u>	<u>SA-516-70</u>	<u>Welded</u>	<u>Side</u>
<u>Inlet</u>	<u>1</u>	<u>16"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>
<u>Outlet</u>	<u>1</u>	<u>16"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>Top</u>
<u>Level Cont.</u>	<u>2</u>	<u>1 1/2"</u>	<u>300#LWN</u>	<u>SA-182-F6</u>	<u>5/8"</u>	<u>-----</u>	<u>"</u>	<u>Side</u>
<u>Cond. Out</u>	<u>1</u>	<u>1 1/2"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>-----</u>	<u>"</u>	<u>Bottom</u>
<u>Guage Gl.</u>	<u>2</u>	<u>1"</u>	<u>"</u>	<u>"</u>	<u>9/16"</u>	<u>-----</u>	<u>"</u>	<u>Side</u>

12. Supports: Skirt No Lugs \_\_\_\_\_ Legs 6 Other \_\_\_\_\_ Attached Bott. of Shell-Welded  
(Yes or no) (No.) (No.) (Describe) (Where and how)

13. Remarks: Note: Heads, shell & plate nozzles material; SA-516-70 W/ 5/64 Min. TP410S S.S. Clad. (Thickness includes Cladding)

**CERTIFICATE OF COMPLIANCE**

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date 11-17-77 Signed The Stacey Manufacturing Co by Henry H C Lig  
(Manufacturer) (Representative)

"U" Certificate of Authorization No. 1830 expires March 30, 19 79

**CERTIFICATE OF SHOP INSPECTION**

Vessel made by The Stacey Manufacturing Co. at Cincinnati

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Ohio and employed by Royal Globe Ins. have inspected the pressure vessel described in this Manufacturers' Data Report on DEC 21 19 77, and state that,

to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Signed Tom Matthews Date 12/21/77 Commissions NO 4466 PENN WC 1720  
(Inspector) (Nat'l Board, State, Province and No.)