

FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS
 (Alternate Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured by HAPPY DIVISION, THERMA TECHNOLOGY / TULSA, OKLAHOMA
 2. Manufactured for PHILADELPHIA PA.
 3. Location of Installation PHILADELPHIA PA.
 4. Type HORIZONTAL 3416-1-2 C-17886 944 (Year Built) 1977
 (Horiz. or vert. tank) (Mfr's Serial No.) (CRN) (Drawing No.) (Nat'l Bld No.)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1974 and Addenda to 12-31-76 and Code Case Nos. _____
 (Year) (Date)

Special Service per UG-120(d) _____
 Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:

6. Shell: Matl. No Shell Nom. Thk. _____ Corr. in. Allow. _____ in. Diam. _____ in. Lgth. _____ ft _____ in.
 (Spec. No., Grade)
 7. Seams: Long. Welded R.T. No Efficiency _____ % H.T. Temp. 1100 F Time 1.125 hr
 (Welded, Dbl, Sngl. Lap, Butt) (Spot or Full)
 Girth Welded R.T. No No. of Courses _____
 (Welded, Dbl, Sngl. Lap, Butt) (Spot, Partial, or Full)

8. Heads: (a) Material SA-516-70 (b) Material SA-515-70
 (Spec. No., Grade) (Spec. No., Grade)
 Location (Top, Bottom, End) Min. Thk. Corr. Allow. SEE FORM U-4 Flat Diam. Side to Pressure (Convex or Concave)
 (a) T & P Sht Max Span = _____ Flat
 (b) Wrapper Sht Max Span = _____ Flat

If removable, bolts used (describe other fastenings) _____

9. Constructed for max. allowable working pressure 480 (Material, Spec. No., Gr. Size, No.)
 psi at max. temp. 650 F. Hydrostatic ~~working~~ test pressure 720 psi.
 (less than -20 F)

10. Safety Valve Outlets: Number _____ Size _____ Location _____

11. Nozzles and Inspection Openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Matl.	Nom. Thk.	Reinforcement Matl.	How Attached	Location
Inlet	2	6"-300#	RFLWN	SA-105	SCH 80	Weld	Welded @	Front Head
Outlet	2	4"-300#	RFLWN	SA-105	SCH 160	Weld	Welded @	Back Head
Vent	1	1"-300#	RFLWN	SA-105		Weld	Welded @	Back Head
Drain	1	1"-300#	RFLWN	SA-105		Weld	Welded @	Front Head
Inlet	2	6"	SEACE	SA-234-WPB	SCH 80	Weld	Welded @	Front Head
Outlet	2	4"	PIPE	SA-106-B	SCH 160	Weld	Welded @	Back Head

12. Supports: Skirt _____ Lugs 4 Legs _____ Other _____ Attached Welded to Tube Sht
 (Yes or no) (No.) (No.) (Describe) (Where and how)

13. Remarks: Box Header at Tube Ends 5 Row, 3 Pass, Tubes; Mat'l SA-214
 Qty 273 O.D. 1" X 0.85 MW X 32'-0" Long.
 F.W. REQ. NO. 1776-1231-A
 P.G.W. EQUIP NO. 2-154-03 ITEM NO. E-102
 Unit Service: REACTOR EFFLUENT COOLER

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.
 Date Oct. 17, 1977 Signed Happy Div. Therma-Tech. by Charles P. Latvala
 (Manufacturer) (Representative)
 "U" Certificate of Authorization No. 10,491 expires MAY 11 1980

CERTIFICATE OF SHOP INSPECTION

Vessel made by Happy Div. Therma-Technology at Tulsa, Oklahoma
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Arkansas and employed by Com. Union Ins. Co have inspected the pressure vessel described in this Manufacturers' Data Report on 10-13 1977, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Signed Frank E. Slaght Date 10-18-77 Commissions N.B. 7935
 (Inspector) (Nat'l Board, State, Province and No.)

2-2

FORM U-4 MANUFACTURERS' DATA REPORT SUPPLEMENTARY SHEET
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

- 1. Manufactured by HAPPY DIVISION, THERMA TECHNOLOGY / TULSA, OKLAHOMA
(Name and address of manufacturer)
- 2. Manufactured for PHILADELPHIA, PA.
(Name and address of purchaser)
- 3. Location of Installation PHILADELPHIA, PA.
(Name and Address)
- 4. Type HORIZONTAL Vessel Number 3416-1-2 --- C-17886 944
Horiz, Vert. Tank, etc. Mfgr. serial CRN Dwg Natl. Bd. No.
- Year Built 1977

Data Report Item Number	Min. Thk.	Corr. Allow.	Remarks	Side to Pressure (Convex or Concave)
LOCATION			Flat Diam.	
8. (a) Top Front T & P Sht	1 1/8"	1/8"	Max Span= 3 15/16" (4 15/16"x11'-6")	Flat
(b) Top Front Wrapper Sht	5/8"	1/8"	Max Span= 4 1/4" (3 3/4"x11'-6")	Flat
(a) Bottom Front T & P Sht	1 1/8"	1/8"	Max Span= 6 1/8" (7 1/8"x11'-6")	Flat
(b) Bottom Front Wrapper Sht	5/8"	1/8"	Max Span= 4 1/4" (3 3/4"x11'-6")	Flat
(a) Bottom Back T & P Sht	1 1/8"	1/8"	Max Span= 1 3/4" (2 3/4"x11'-6")	Flat
(b) Bottom Back Wrapper Sht	5/8"	1/8"	Max Span= 4 1/4" (3 3/4"x11'-6")	Flat
(a) Top Back T & P Sht	1 1/8"	1/8"	Max Span= 8 3/8" (9 3/8"x11'-6")	Flat
(b) Top Back Wrapper Sht	5/8"	1/8"	Max Span= 4 1/4" (3 3/4"x11'-6")	Flat

R. B. BILLINGSLEY
INSPECTOR
PROCESS PLANTS DIVISION
POSTER WHEELER ENERGY CORP.

Date Oct 17, 1977 HAPPY DIVISION THERMA-TECHNOLOGY Signed Charles P. Latrela
Manufacturer

Date 10-18-77
Authorized Inspector's Signature [Signature] Commission N.B. 7935
Natl. Brd, State, Province and No.