


Manway Cover Detail



Outside Dia	33-1/8"
No of bolts:	24
Bolt length:	9"
Bolt dia.:	1-1/4"
Nom. size:	300#
Rating:	20"
Type:	Long Neck

Inches from Head

U-1 on hand **YES**
 Heat Treat **NO**
 X-Ray **YES**

Tank Openings

Tank Details

Description

Dimensions

O/A Length	A -	54' 6-1/2"
Length - weld to weld	B -	44' 6-1/2"
Diameter of Tank	O. D. C -	10' 2-1/4"
Weld to End	D -	5'
Width of Piers	E -	16"
C/C of Piers	F -	33' 7"
C/L of Piers to Weld end	G -	52"
	H -	36"

No	Size	Type	Description	Tank Details		Description		Dimensions	
1	3"	300#	36	Liquid Out	Manufacturer:	Sistersville	Type of Head	HEMI	
2	1-1/4"	NPT	Head	Thermowell	Date of manufacture	1958	Tank Capacity	USWG	30,000
3	2-1/2"	Flg	Head	Magnatel 8-bolt mount	Working Pressure	250	Tank Weight	estimated	70,000
4	3/4"	NPT	Head	Pressure Gauge	National Board Number	938	Tank Shell		1"
5	18"	300#	45	Manway	Serial Number	8328-3	Tank Head		1/2"
6	4"	300#	15'	MultiPort Mount	Steel Type:		Pier Type (Concrete / saddles / Flat)	Conc	
7	4"	300#	14' 4"	MultiPort Mount	Jurisdiction #		Tank Saddles	None	
8	2"	PIPE	M/W	Liquid	Gauge type	Magnatel			
9	2"	PIPE	M/W	Liquid	Thermometer	None			
10	1-1/4"	PIPE	M/W	Vapor	Paint Condition:	Fair			
11	1-1/4"	PIPE	M/W	Vapor	Color:	White			
12					Relief Valve Type	MultiPort	Information taken by:		
13					Test Date	1996	Date:		
14							Tank Location	Beacon Falls #8	