



Total Energy Corp

Tank Sketch of field Informations



No U-1 on hand

Manway Cover Detail



No of bolts:
Bolt length:
Bolt diamet:
C/C of studs:
Circle:
Nom size:
Rating:

Note: 20" OD

Forward copies of any certificates, affidavits and drawings if available
Show size and location of all openings
Show all horizontal and vertical welds on shell, locate and show manway on tank
Locate size and identify all openings in manway cover detail
Show length, with, height and bolt centers of steel saddles where used

Description		Dimensions	
O/A Length		A -	66'
Length - weld to weld		B -	57' 6"
Diameter of Tank	O. D.	C -	108"
Weld to End		D -	4' 6"
Width of Piers		E -	22"
C/C of Piers		F -	41'11"
C/L of Piers to Weld end		G -	7' 10"
		H -	7' 9"
		K -	
Ht. of tank above grade			

Tank Openings

Tank Details

No	Size	Type		Description					
1	3"	Thr.	Liq.	centered 8.5" from head seam	Manufacture:	Atlas tank mfg.	Type of Head		hemi
2	2"	Thr.	Liq.	centered 20.5" from head seam	Date of man.	1973			
3	2"	Thr.	vapor	centered 32.5" from head seam	Retest Date:		Tank Capacity	USWG	30,000
4	1/2"	Thr.		thermometer	Working Pressure	250 @ 125	Tank Weight		
5	2"	Thr.	vapor	centered 8" from head seam	NB #		Tank Shell		0.778
6	2"	Thr.	vapor	centered 20" from head seam	Serial #	ST 1372	Tank Head		0.436
7	2"	Thr.	vapor	centered 32" from head seam	Steel Type:				
8	2 1/2"	Thr.		magnetic gauge	ASME # :		Pier Type	(Concrete / saddles / Flat)	
9	1/4"	Thr.		Pressure gauge	Provincial #		Tank Saddl	Concrete	
10	2"	Thr.	vapor	centered 9" from head seam	Fixed Liquid Level gauge				
11	1/4"	Thr.		85% Float Gauge:					
12	1"	Thr.		Plug	Thermometer		History before the last moved		
13					Paint Condition:	good	Drawn by:		
14					Color:	white	Drawn #		
15					Relief Valves		Information taken by:		
16					Multi Port or Screwed	3 screwed	Date:		
17					Test Date		Tank Location		Clemson, SC.