

FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS

Alternate Form For Single Chamber Completely Shop Fabricated Vessels Only

As required by the Provisions of the ASME Code Section VIII — Division I and the National Board

1. Manufactured by RILEY BEAIRD, INC., SHREVEPORT, LOUISIANA
(Name and address of Manufacturer) SHIP C/O SOUTH CAROLINA ELEC. & GAS
2. Manufactured for APPLIED ENGINEERING CO. ORANGEBURG, S.C. COLUMBIA, SOUTH CAROLINA
(Name and address of Purchaser)
3. Type Horiz. Vessel No. (102974-01-8) (Mfrs. Serial) (State & Std. No.) Nat'l Bd. No. 20417 Yr. Built 1973
(Horiz. or Vert.)
4. SHELL: Mat'l SA-612-B.T.S. 81,000# ^{Nom.} Thk. 13/16 in. ^{Corr.} Allow. 0 in. Diam. 10 ft. 10-1/4 in. Length 79 ft. 3-1/2 in.
(Kind and Spec. No.) (Flg. or F. B. & Spec. Min. T.S.)
5. SEAMS: Long Dbl. Butt HT No R.T. Complete Sectioned No Efficiency 100 %
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)
- If riveted or brazed describe seams fully under remarks.
- Girth Dbl. Butt HT No R.T. Complete Sectioned No No. of Courses 11
6. HEADS: (a) Material SA-612-A T.S. 83,000# (b) Material _____ T.S. _____
- * Location (Top, bottom, ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)
- (a) Ends 15/32" _____ _____ _____ _____ _____ 65.1347" Concave
- (b) _____
- If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)
7. Constructed for max. allowable working press. 250 psi. at max. temp. 100 °F Min. temp. (when less than -20°) _____ °F. ^{Hydrostatic Test Press.} 375 psi.
8. SAFETY OR RELIEF VALVE OUTLETS: Number 3 Size 4-1/8" Location In manway cover
9. NOZZLES: (3) 4-1/8" Openings drilled in manway cover
- | Purpose (Inlet, Outlet, Drain) | Number | Diam. or Size | Type | Material | Thickness | Reinforcement Material | How Attached |
|------------------------------------------------|--------|---------------|------|----------------------|-----------|------------------------|--------------|
| (1) 1" 3000# Cplg. | | | | F.S. | | | Welded |
| (1) 2-1/2" Special Flg. for Float Gage Adapter | | | | SA-515-70 & SA-106-B | | | Welded |
| (1) 1" x 1/4" 3000# Reducing Cplg. | | | | SA-105-II | | | Welded |
| (1) 3/4" Sch. 80 Seamless Pipe (Thermowell) | | | | SA-106-B | | | Welded |
| (2) 2" (2) 3" 300# Pad Type Cplgs. | | | | SA-515-70 | | | Welded |
10. INSPECTION Manholes, No. 1 Size 18" Location 300# Pad Type SA-105-71
 OPENINGS Handholes, No. _____ Size _____ Location Top of tank
 Threaded, No. _____ Size _____ Location _____
11. SUPPORTS: Skirt _____ Lugs _____ Legs _____ Other (2) Saddles Attached Welded to tank
(Yes or No) (Number) (Number) (Describe) (Where & How)
12. REMARKS: 130-1/4" I.D. x 90' 0-1/2" O.A. Length 59,775 W.G. Propane Storage Tank, per Riley Beard, Inc. Dwg. Order 102974-01
* Head seams spot X-rayed Joint Eff. 85%

(Brief description of purpose of the vessel, as Air Tank, After Cooler, Jacketed Cooker, etc. State contents.)

1 If Postweld Heat Treated 2 list other internal or external pressures with coincident temperature when applicable.

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Unfired Pressure Vessels, Section VIII, Division I, 1971 Edition

Date 11-28 1973 Signed RILEY BEAIRD, INC. By [Signature]
(Manufacturer)

Certificate of Authorization Expires March 12, 1976

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY RILEY BEAIRD, INC. at SHREVEPORT, LOUISIANA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by COMMERCIAL UNION INSURANCE CO. of _____ have inspected the pressure vessel described in this manufacturer's data report

on 11-28 1973 and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____
[Signature]
 Inspectors Signature

Commissions N. B. COMM. 1860
 Nat'l Board, State, Province and No.