



# Total Energy Corp

# Tank Sketch of field Information



## Manway Cover Detail



Outside Dia	
No of bolts:	
Bolt length:	
Bolt dia.:	
Nom. size:	
Rating:	
Type:	
Height of above shell:	

U-1 on hand  
Heat Treat  
X-Ray

**NO**  
**NO**  
**PARTIAL**

## Tank Openings

## Tank Details

## Description

## Dimensions

O/A Length	A -	69' 11-3/8"
Length - weld to weld	B -	60' 10"
Diameter of Tank	O. D. C -	9' 1-3/8"
Weld to End	D -	54-7/8"
Width of Piers	E -	16"
C/C of Piers	F -	44' 5"
C/L of Piers to Weld end	G -	100-1/2"
	H -	96-1/2"

## No Size Type

## Description

1	3"	NPT	12	Liquid Out	Manufacturer:	Trinity	Type of Head	Hemi	
2	2"	NPT	24	Capped	Date of manufacture	1974			
3	2"	NPT	36	Vapor			Tank Capacity	USWG	30,000
4	3/4"	NPT		Thermowell	Working Pressure	250	Tank Weight	estimated	
5	2-1/2"	NPT		Magnatel	National Board Number	NONE	Tank Shell		0.673
6	3/4"	NPT		Max fill / pressure gauge	Serial Number	394263	Tank Head		0.4375
7	2"	NPT	6	Pressure relief	Steel Type:				
8	2"	NPT	18	Pressure relief			Pier Type (Concrete / saddles / Flat)		Concrete
9	2"	NPT	30	Pressure relief	Jurisdiction #		Tank Saddles		None
10	2"	NPT	48	Plugged					
11	1"	NPT		Roto-Gauge	Gauge type	Magnatel and Rotary			
12	3"	NPT	12	Liquid Out	Thermometer	Dial			
13	2"	NPT	24	Capped	Paint Condition:	Poor			
14	2"	NPT	36	Vapor	Color:	White			
15							Information taken by:		GB / TM
16					Relief Valve Type	Internal	Date:		8/13/2008
17					Test Date	N/A	Tank Location		#3 Bay Shore, NY