



commerce.wi.gov

# Regulated Object Inspection Report

SAFETY AND BUILDINGS DIVISION  
 Inspection and Safety Support Section  
 P. O. Box 7302  
 Madison, Wisconsin 53707-7302  
 www.commerce.state.wi.us

Personal information you provide may be used for secondary purposes [Privacy Law, s.15.04 (1)(m), Stats.]

<b>Owner and/or Billing Contact Info:</b>		<b>Object Location:</b>		Investigation ID		Regulated Object ID	
Name: Total Energy Robert Armintano		Site: Genreal Motors		Date Inspected 12/21/09		Inspection Fee	
Address: PO Box 757 2 Hard Scrabble Road		Address: 1000 Industrial Drive		Special Fee		PTO Fee	
City/Zip: North Salem NY 10560		City: Janesville		PTO Action:			
Phone: (866) 857-9945		State/Zip: WI 53546		Total Fees			
		County: 53-ROCK		Investigation Kind:			
		Location on Property:					
<b>Regulated Object Information</b>				<b>Attributes</b>			
WI Registration Tag Number:				Container Surface Area:		Max Working Pressure:	
Family: Fuel, S&B				Use:		Safety Valve Set: Capacity:	
Type: Liquefied Petroleum Gas Systems/Equipment				Manufacturer:		Pressure Test: PSI:	
Last Investigation: Cycle: N/A				Manufacturer ID:		Refrigerated Storage:	
PTO Expiration: Next:				Year Built:		Occupancy Type:	
History:				Container Capacity:			
Inspector Name: Jon P Wolf email – jon.wolf@wisconsin.gov Wisconsin Credential Number: 100112 I certify this is a true and accurate report of my inspection.			Employed by: PO Box 64 Lake Mills, WI 53551			Onsite Contact: Gary Moser	
			Phone: (920) 723-0032			Contact's Phone:	
			Fax: (608) 828-3743			Contact's Email: gdpetro9@aol.com	
<b>Remarks:</b> THIS IS AN UPDATED REPORT INCLUDING ALL OF THE EIGHT 30,000 GALLON PROPANE TANKS INSPECTED AT ABOVE LOCATION.				<b>Invoice:</b>			
Item No	Code Section	<b>Code violations listed below shall be corrected by COMPLIANCE DATE: *</b> *See the bottom of this report for important compliance information regarding this ORDER.					
1		<p>Inspected 8 - 30,000 gallon propane tanks at the General Motors, Janesville plant. Tank #5 thru 8 did not have a national board number all tanks are listed below.</p> <p>#1 Chicago Bridge &amp; Iron Co., ASME 30,000 gal. Propane type, U-69, 200psig, National Board # 1730 Mfg Serial No. C-2017, year built: 1949. Has MDR.</p> <p>#2 Chicago Bridge &amp; Iron Co., ASME 30,000 gal. Propane type, U-69, 200psig, National Board # 1729 Mfg Serial No. C-2016, year built: 1949. Has MDR.</p> <p>#3 Bethlehem Steel Company., ASME 30,000 gal. Propane type, U-69, 200psig, National Board # 708, Mfg Serial No. 943, year built: 1948. Has MDR.</p> <p>#4 Tank did have a National Borad number but the National Board does not have record (MDR) for this tank. Superior Welding Co., National Board # 3492, ASME 30,000 gal. Propane type, 250psig, Mfg Serial No. 5295, year built 1957.</p> <p>#5 Atlas Tank Mfg Co., ASME 30,000 gal. Propane type, 250psig, Mfg Serial No. ST108, year built: 1971</p> <p>#6 Atlas Tank Mfg Co., ASME 30,000 gal. Propane type, 250psig, Mfg Serial No. ST107, year built: 1971</p> <p>#7 Trinity Industries, Inc., ASME 30,000 gal. Propane type, 250psig, Mfg Serial No. 375607, year built: 1971</p> <p>#8 Atlas Tank Mfg Co., ASME 30,000 gal. Propane type, 250psig, Mfg Serial No. ST1082, year built: 1970</p>					

**IMPORTANT:** This DEPARTMENT ORDER is issued as a result of an inspection on the above referenced site. You are hereby ordered to have the violations corrected to conform to the indicated provisions of the Wisconsin Administrative Code and/or Statutes. These violations must be corrected by the compliance date noted, and upon correction of violations the inspector must be notified. If you fail to comply, this order is enforceable in circuit court pursuant to s. 101.02(13), Stats., with forfeitures ranging from \$10 to \$100 per day for each violation. In addition, the Department may attach a notice of violation to the deed for the property on which the violations occur. If you have any questions regarding this matter, please feel free to contact the inspector at the number listed on this report.