



Item 20 Remarks: National Board Classification equals 528 Sq. Ft. Bursting Pressure equals 1000# psi. Hammer Test @ 313 psi. 250 psi Working Pressure. Factor of Safety equals 4 Per UW-1956 Code.

We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this unfired pressure vessel conform to the ASME Code for Unfired Pressure Vessels.

Date: 4-24-58 Signed Chicago Bridge & Iron Co. (Manufacturer) By: [Signature]

Certificate of Authorization Expires: 035 Dec 31, 1961

### CERTIFICATE OF SHOP INSPECTION

Insurance Company's Serial Number 3953  
VESSEL MADE BY Chicago Bridge & Iron Co. at Birmingham, Alabama  
I, the undersigned, holding a Certificate of Competency as an Inspector of Boilers and Unfired Pressure Vessels in THE STATE OF [State] and employed by THE HARTFORD STEAM BOILER INSPECTION AND INSURANCE COMPANY of HARTFORD, CONN., inspected internally and externally, the vessel described in this report on 4-24-58 and certify that the statements made in this report are correct, corresponding with mill test reports of materials furnished by the manufacturer and measurements made of the vessel; and that this vessel is constructed in accordance with the ASME Code for Unfired Pressure Vessels.

Date: 4-24-58  
Inspector's Signature: William J. White  
Commissions: N.B. 1858  
State or Nat'l Bd. # Number: [Blank]

### CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a Certificate of Competency as an Inspector of Boilers and Unfired Pressure Vessels in THE STATE OF [State] and employed by [Company], have compared the statements in this manufacturer's data report with the completed vessel, and certify that parts referred to as data items were completed in the field in accordance with the requirements of the ASME Code for Unfired Pressure Vessels. The completed vessel was inspected and subjected to a hydrostatic test of [ ] psi.

Date: 10- [ ]  
Inspector's Signature: [Blank]  
Commissions: [Blank]  
State or Nat'l Bd. # Number: [Blank]