

BSCo. 7319 (T-2) for Anco Manufacturing & Supply Co. FORM U-1 MANUFACTURERS' DATA REPORT FOR UNFIRED PRESSURE VESSELS As Required by the Provisions of the A.S.M.E. Code Rules

A.S.M.E.

BETHLEHEM STEEL COMPANY, BETHLEHEM, PA.

T-98-52-214

- 1. Manufactured by... 2. Manufactured for... 3. Type Horizontal... 4. Have mill test reports... 5. SHELL OR DRUMS... 6. STAMPS on shell plates... 7. SHELL PLATE... 8. DIAMETER of rivet holes... 9. GIRTH JOINTS... 10. IRON SHELL... 11. HEADS: Flat or dished...

Table with columns: STAYS, No., Size, Net Area, Welded or Bolted, Area to be Stayed, and Allowable Working Pressure. Includes rows for F.H., R.H., Through, and Diagonal and Gusset Stays.

- 13. STAY BOLTS... 14. Maximum pitch... 15. SAFETY VALVE outlets... 16. FUSIBLE PLUG... 17. OUTLETS... 18. DRAIN CONNECTION... 19. MANHOLES... 20. NONPRESSURE PARTS... 21. Bursting pressure... 22. Constructed for pressure of...

Remarks: 30,000 gal. propane storage tank, Hammer tested at 313... Constructed to meet ASME 1949 code, para. U69 for 200 p.s.i., also complies with para. U201 for 250 p.s.i. and ASME 1950 code, section III for 250 p.s.i.

Certificate of authorization expires 12/31/52

We certify the above data to be correct and that all details of material, construction, and workmanship on this unfired pressure vessel conform to the A.S.M.E. Code for Unfired Pressure Vessels. Date: 9/10/52 Signed: BETHLEHEM STEEL COMPANY