

FORM U-1A MANUFACTURERS' DATA REPORT FOR UNFIRED PRESSURE VESSELS

Alternate Form for Single Chamber Completely Shop-Fabricated Vessels Only

1. Manufactured by MASTER TANK & WELDING DALLAS, TEXAS
(Name and address of Manufacturer)

2. Manufactured for AGRICULTURAL CHEMICAL EQUIPMENT COMPANY
(Name and address of Purchaser)

3. Type Horiz. Vessel No. (96520) ((Mfr. Serial)) ((State & State No.)) Natl. Bd. No. 3759 Yr. Built 1969

4. SHELL: Matl. SA-515-70 T.S. 70,000 Nom. 15/16 Corr. 0 In. Allow. 0 In. Diam. 11 Ft. 0 In. Length 47 Ft. 1 In. O.D.

5. SEAMS: Long D.B. Weld H.T. No X.R. Spot Sectioned NO Efficiency 85 %
(Welded, Dbl., Mig, Lap, Butt) (Yes or No) (Spot or Complete) (Yes/No)

6. HEADS: (a) Material SA-455-B FLG. 0 T.S. 73,000 (b) Material SA-455 FLG. 0 T.S. 73,000

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a) End	.528"					66"		Concave
(b) End	.528"					66"		Concave

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)

If riveted or brazed describe seams fully under remarks.

7. Constructed for max. allowable working pres.¹ 250 psi. at max. temp. 100 °F. Min. temp. (when less than -20°) _____ Hydrostatic Test 375 psi.
°F. Temperature

8. SAFETY OR RELIEF VALVE OUTLETS: Number 3 Size 2" Location On head

9. NOZZLES: *(See one listed below)

Purpose (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
85% L.L.G. & P.G.	1	3/4"	Cplg.	SA-105-II			Welded
Float Gage	1	2-1/2"	Cplg.	SA-105-II			Welded
Thermowell	1	3/4"	Smls. Pipe	Sch 80			Welded
15% L.L.G.	1	1/4"	Cplg.	SA-105-II			Welded
Vapor	3	2"	Cplg.	SA-105-II			Welded
Liquid	2	3"	Cplg.	SA-105-II			Welded

10. INSPECTION MANHOLES, No. 1 Size 18" Location On head

OPENINGS: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____

11. SUPPORTS: Skirt No Lugs _____ Legs _____ Other Saddles Attached Welded to Shell
(Yes or No) (Number) (Number) (Describe) (Where & How)

12. REMARKS: s/o 8350 Dwg. # R-1144-C 30,000 W.G. Cap. Freon Storage Tank

*Liquid 1 2" Cplg. SA-105-II Welded
(Brief description of purpose of the vessel as Air Tank, Water Tank, L.P.G., Etc.—State Contents. ¹ If postweld heat-treated. ² List other internal or external pressures with coincident temperature when applicable.)

To certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Unfired Pressure Vessels.

Date JUL 18 1969 19 Signed MASTER TANK & WELDING *[Signature]*
(Manufacturer)

Certificate of Authorization Expires 12/31/70

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY MASTER TANK & WELDING at DALLAS, TEXAS

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of TEXAS and employed by HARTFORD STEAM BOILER INSP & INS of HARTFORD, CONN. have inspected the pressure vessel described in this manufacturer's data report on JUL 18 1969 1969 and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date JUL 18 1969 *[Signature]* A. J. DUTTON - TNS 13
N.B. 03072